EPL Number:

В **Monitoring and Complaints Summary**

1/06/2022 1/07/2022 Period: to



4 July 2022

0

Number of Pollution Complaints B1

> **Pollution Category Number of Complaints** 0 Air 0 Water Noise 0 0 Waste Other 0

555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&o

ption=licence&searchrange=licence&range=POEO%20licence&prp=no&stat

us=Issued

B2 Concentration Monitoring Summary

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	1/06/2022	4	4	4	20
Total suspended solids	milligrams per litre	Special Frequency 1	1	1/06/2022	22	22	22	30

Comments:

Monitoring Point 4: Ambient water monitoring

Pollutant			No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	10.8	13.2	15.4	NA*



Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply

to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

4 July 2022

Discharge and Monitoring Point 5: Discharge water quality monitoring

Pollutant	Unit of		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	11.9	14.9	17.4	35

Comments: Periods where the plant is offline have been removed from this data set.

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	10.3	13.2	16.6	NA*



Comments: n/a 4 July 2022

Monitoring Point 7: Ambient water monitoring

Pollutant	Unit of		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	10.7	13.1	15.8	NA*

Comments: n/a

Monitoring Point 8: Discharge water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Copper	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*
Nitrogen (total)	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
рН	рН	Monthly during discharge	0	-	-	-	-	NA*
Total Phosporous - filtered sample	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Total suspended solids	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Zinc	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*



4 July 2022

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply

to receiving waters

Comments: No discharge this month.

Discharge and Monitoring Point 9: Air emissions monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Carbon dioxide	%	Continuous	**	NA	3.3	3.9	4.5	NA
Moisture content	Percent	Continuous	**	NA	6.7	7.7	8.9	NA
Nitrogen oxides	parts per million	Continuous	**	NA	4.8	10.0	13.8	25
Oxygen (O2)	Percent	Continuous	**	NA	12.2	13.3	14.2	NA
Solid particles	milligrams per cubic metre	Yearly	1	9/11/2021	-	<0.4	-	10
Sulphur dioxide	parts per million	Yearly	1	9/11/2021	-	<2	-	3
Temperature	Degrees Celsius	Continuous	**	NA	69.2	83.8	90.0	NA
Volatile organic compounds	parts per million	Yearly	1	9/11/2021	-	0.0079	-	NA
Volumetric flow rate	cubic metres per second	Continuous	**	NA	218.7	384.0	446.0	NA



Notes:

* equipment detection limit

Comments:

B3 Volume or Mass Monitoring Summary

Energy Australia

4 July 2022

Monitoring Point 3: Sewage volume monitoring

P		Unit of		No. of samples collected	Date Samples collected	Lowest result	Mean result	Highest result	Licence Limit
S	Sewage	Kilolitres per day	Continuous	**	NA	0	7	63	100

Notes:

** Continuous data recorded via inline flow meter

Comments: