

Monthly Summary Report

EPL Number: 13007
 EPL Holder: EnergyAustralia NSW
 EPL Name of facility: MOUNT PIPER POWER STATION
 EPL Address of facility: 350 BOULDER ROAD, PORTLAND, NSW 2847
 EPL Website link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=156231&SYSUID=1&LICID=13007>
 EPL Monitoring locations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Unit of measure abbreviations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Period monitored: May 2019
 Monthly Summary Status: Complete: all monitoring data obtained

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Number of times monitored in month	Min. Value	Mean Value	Median Value	Max. Value	100 Percentile limit	Exceedance	Published Date	Comment
LDP3	Nitrogen Oxides	g/m3	Continuous during discharge	Continuous	0.32	0.613	0.58	1.07	1.5	No	13/6/2019	
LDP1	Oil and Grease	mg/L	Monthly during discharge						10	No	13/6/2019	Not sampled: due to no flow / no discharge.
LDP1	pH	pH	Monthly during discharge							No	13/6/2019	Not sampled: due to no flow / no discharge.
LDP1	Total suspended solids	mg/L	Monthly during discharge							No	13/6/2019	Not sampled: due to no flow / no discharge.
LDP2	Nitrogen Oxides	g/m3	Continuous during discharge	Continuous	0.5	0.742	0.64	1.07	1.5	No	13/6/2019	Not sampled: due to no flow / no discharge for the period 1/5/2019 to 25/5/2019.
LDP2	Sulphur dioxide	mg/m3	Continuous during discharge	Continuous	1085	1099	1101	1114		No	13/6/2019	Not sampled: due to no flow / no discharge for the period 1/5/2019 to 25/5/2019.
LDP3	Sulphur dioxide	mg/m3	Continuous during discharge	Continuous	974	1030	1030	1085		No	13/6/2019	

Monthly Exceedance Table

EPL Number: 13007
 EPL Holder: EnergyAustralia NSW
 EPL Name of facility: MOUNT PIPER POWER STATION
 EPL Address of facility: 350 BOULDER ROAD, PORTLAND, NSW 2847
 EPL Website link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=156231&SYSUID=1&LICID=13007>
 EPL Monitoring locations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Unit of measure abbreviations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Period monitored: May 2019

Sample Date	Licensed Monitoring Point Code	Pollutant	Unit of Measure	Sample Value	100 Percentile Limit	Exceedance	Comment
NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL

Monthly Correction Log

EPL Number: 13007
 EPL Holder: EnergyAustralia NSW
 EPL Name of facility: MOUNT PIPER POWER STATION
 EPL Address of facility: 350 BOULDER ROAD, PORTLAND, NSW 2847
 EPL Website link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=156231&SYSUID=1&LICID=13007>
 EPL Monitoring locations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Unit of measure abbreviations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Period monitored: May 2019

Sample Date	Licensed Monitoring Point Code	Pollutant	Unit of Measure	Original Data	Corrected Data	Date Corrected	Date Originally Published	Reason
NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL	