



EnergyAustralia
LIGHT THE WAY

B Monitoring and Complaints Summary

Period: 1/04/2024 to 1/05/2024

B1 Number of Pollution Complaints 0

Pollution Category	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: <http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued>

14 May 2024

B2 Concentration Monitoring Summary

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	25/03/2024	4	4	4	20
Total suspended solids	milligrams per litre	Special Frequency 1	1	11/04/2024	16	16	16	30

Comments:

Monitoring Point 4: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	20.1	20.9	21.6	NA*



Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

14 May 2024

Discharge and Monitoring Point 5: Discharge water quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	15.3	18.0	23.7	35

Comments: Periods where the plant is offline have been removed from this data set.

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	17.1	20.3	24.8	NA*

Comments: n/a

**EnergyAustralia**

LIGHT THE WAY

14 May 2024

Monitoring Point 7: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	17.5	20.4	25.1	NA*

Comments: n/a

Monitoring Point 8: Discharge water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Copper	micrograms per litre	Monthly during discharge	1	11/04/2024	0.002	0.002	0.002	NA*
Nitrogen (total)	milligrams per litre	Monthly during discharge	1	11/04/2024	3.3	3.3	3.3	NA*
pH	pH	Monthly during discharge	1	11/04/2024	7.6	7.6	7.6	NA*
Total Phosphorous - filtered sample	milligrams per litre	Monthly during discharge	1	11/04/2024	1.08	1.08	1.08	NA*
Total suspended solids	milligrams per litre	Monthly during discharge	1	11/04/2024	11	11	11	NA*
Zinc	micrograms per litre	Monthly during discharge	1	11/04/2024	<0.005	<0.005	<0.005	NA*

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply to receiving waters

Comments:



EnergyAustralia

LIGHT THE WAY

14 May 2024

Discharge and Monitoring Point 9: Air emissions monitoring

Pollutant	Unit of Measure	No. of Samples required	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Moisture content	Percent	Continuous	8.0	8.4	8.7	NA
Nitrogen oxides	parts per million	Continuous	8.5	9.1	10.2	25
Oxygen (O2)	Percent	Continuous	13.1	13.3	13.8	NA
Temperature	Degrees Celsius	Continuous	83.5	88.8	92.2	NA
Volumetric flow rate	cubic metres per second	Continuous	285.0	375.3	422.6	NA



EnergyAustralia

LIGHT THE WAY

14 May 2024

Discharge and Monitoring Point 13: Air emissions monitoring

Pollutant	Unit of Measure	No. of Samples required	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Moisture content	Percent	Continuous	-	-	-	NA
Nitrogen oxides	parts per million	Continuous	-	-	-	25
Oxygen (O2)	Percent	Continuous	-	-	-	NA
Temperature	Degrees Celsius	Continuous	-	-	-	NA
Velocity	Meters per second	Continuous	-	-	-	NA
Volumetric flow rate	cubic metres per second	Continuous	-	-	-	NA

Notes: Plant not in operation

Comments: N/A Not Applicable Plant Not in Operation

**EnergyAustralia**

LIGHT THE WAY

14 May 2024

B3 Volume or Mass Monitoring Summary***Monitoring Point 3: Sewage volume monitoring***

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date Samples collected	Lowest result	Mean result	Highest result	Licence Limit
Sewage	Kilolitres per day	Continuous	**	NA	0	12	37	100

Notes: ** Continuous data recorded via inline flow meter

Comments: