



**EnergyAustralia**  
LIGHT THE WAY

## B Monitoring and Complaints Summary

Period: 1/10/2023 to 1/11/2023

### B1 Number of Pollution Complaints 0

Pollution Category	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

EPL Number: 555  
 Licensee's name: ENERGYAUSTRALIA TALLAWARRA  
 Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530  
 Link to EPL: <http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued>

17 November 2023

### B2 Concentration Monitoring Summary

#### *Monitoring Point 2: Effluent quality monitoring*

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	0	-	-	-	-	20
Total suspended solids	milligrams per litre	Special Frequency 1	0	-	-	-	-	30

Comments:

**Monitoring Point 4: Ambient water monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	17.6	20.3	23.0	NA*



Notes: \*Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

17 November 2023

**Discharge and Monitoring Point 5: Discharge water quality monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	14.2	18.3	25.3	35

Comments: Periods where the plant is offline have been removed from this data set.

**Monitoring Point 6: Ambient water monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	15.2	20.0	24.2	NA*

Comments: n/a



17 November 2023

**Monitoring Point 7: Ambient water monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	16.1	20.2	23.4	NA*

Comments: n/a

**Monitoring Point 8: Discharge water monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Copper	micrograms per litre	Monthly during discharge	1	20/10/2023	<0.001	<0.001	<0.001	NA*
Nitrogen (total)	milligrams per litre	Monthly during discharge	1	20/10/2023	1.90	1.90	1.90	NA*
pH	pH	Monthly during discharge	1	20/10/2023	8.00	8.00	8.00	NA*
Total Phosphorous - filtered sample	milligrams per litre	Monthly during discharge	1	20/10/2023	0.66	0.66	0.66	NA*
Total suspended solids	milligrams per litre	Monthly during discharge	1	20/10/2023	10.00	10.00	10.00	NA*
Zinc	micrograms per litre	Monthly during discharge	1	20/10/2023	<0.005	<0.005	<0.005	NA*

Notes: \*Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply to receiving waters

Comments:



**EnergyAustralia**

LIGHT THE WAY

17 November 2023

**Discharge and Monitoring Point 9: Air emissions monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Carbon dioxide	%	Continuous	**	NA	3.8	4.1	4.3	NA
Moisture content	Percent	Continuous	**	NA	7.6	8.2	8.6	NA
Nitrogen oxides	parts per million	Continuous	**	NA	6.1	8.2	17.2	25
Oxygen (O2)	Percent	Continuous	**	NA	13.1	13.4	13.9	NA
Solid particles	milligrams per cubic metre	Yearly	1	6/12/2022	-	<0.6	-	10
Sulphur dioxide	parts per million	Yearly	1	6/12/2022	-	1.9	-	3
Temperature	Degrees Celsius	Continuous	**	NA	77.5	86.3	93.0	NA
Volatile organic compounds	parts per million	Yearly	1	6/12/2022	-	<1	-	NA
Volumetric flow rate	cubic metres per second	Continuous	**	NA	266.2	342.8	415.8	NA

Notes: \* equipment detection limit

Comments: n/a

**EnergyAustralia**

LIGHT THE WAY

17 November 2023



**EnergyAustralia**  
LIGHT THE WAY

17 November 2023

### B3 Volume or Mass Monitoring Summary

#### *Monitoring Point 3: Sewage volume monitoring*

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date Samples collected	Lowest result	Mean result	Highest result	Licence Limit
Sewage	Kilolitres per day	Continuous	**	NA	0	0	0	100

Notes: \*\* Continuous data recorded via inline flow meter

Comments: