B Monitoring and Complaints Summary

Period: 1/09/2024 to 1/10/2024



B1 Number of Pollution Complaints 0

13 November 2024

Pollution Category	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&o

ption=licence&searchrange=licence&range=POEO%20licence&prp=no&sta

tus=Issued

B2 Concentration Monitoring Summary

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	0	-	,	-	•	20
Total suspended solids	milligrams per litre	Special Frequency 1	0	-	-	-	-	30

Comments:

Monitoring Point 4: Ambient water monitoring

Pollutant			No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	14.0	16.6	18.8	NA*



Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply

to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

13 November 2024

Discharge and Monitoring Point 5: Discharge water quality monitoring

Pollutant	Unit of Measure		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	10.2	14.8	22.2	35

Comments: Periods where the plant is offline have been removed from this data set.

Energy Australia Tallawarra EPL Data

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure	I -	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	12.9	16.6	19.2	NA*



Comments: n/a 13 November 2024

Monitoring Point 7: Ambient water monitoring

Pollutant	Unit of		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	14.1	16.7	18.6	NA*

Comments: n/a

Monitoring Point 8: Discharge water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Copper	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*
Nitrogen (total)	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
рН	рН	Monthly during discharge	0	-	-	-	-	NA*
Total Phosporous - filtered sample	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Total suspended solids	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Zinc	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*



13 November 2024

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply

to receiving waters

Comments: No discharge this month

Discharge and Monitoring Point 9: Air emissions monitoring

Pollutant	Unit of Measure	No. of Samples required	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Moisture content	Percent	Continuous	7.5	8.4	8.8	NA
Nitrogen oxides	parts per million	Continuous	8.5	11.2	17.6	25
Oxygen (O2)	Percent	Continuous	12.9	13.3	14.1	NA
Temperature	Degrees Celsius	Continuous	78.0	90.3	96.1	NA
Volumetric flow rate	cubic metres per second	Continuous	258.8	368.0	428.9	NA

Discharge and Monitoring Point 13: Air emissions monitoring

	Unit of	No. of Samples	Lowest sample	Mean of	Highest sample	Licence
Pollutant	Measure	required	value	sample	value	Limit
Moisture content	Percent	Continuous	10.0	10.0	10.0	NA
Nitrogen oxides	parts per million	Continuous	10.0	13.1	18.0	25
Oxygen (O2)	Percent	Continuous	13.0	13.3	13.7	NA
Temperature	Degrees Celsius	Continuous	616.4	662.8	828.1	NA
Velocity	Meters per second	Continuous	36.8	48.9	60.3	NA
Volumetric flow rate	cubic metres per second	Continuous	327.3	428.1	542.1	NA

Notes: Moisture content subtituted for conservative value of 10%





13 November 2024

B3 Volume or Mass Monitoring Summary

Monitoring Point 3: Sewage volume monitoring

No. of Unit of Samples No. of samples **Date Samples** Lowest Mean Highest Licence collected Measure required collected Pollutant result result result Limit Kilolitres per Continuous ** NA 0 0 0 100 day Sewage

Notes: ** Continuous data recorded via inline flow meter

Comments: