



EnergyAustralia
LIGHT THE WAY

B Monitoring and Complaints Summary

Period: 1/10/2024 to 1/11/2024

B1 Number of Pollution Complaints 0

13 November 2024

Pollution Category	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

EPL Number: 555
 Licensee's name: ENERGYAUSTRALIA TALLAWARRA
 Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530
 Link to EPL: <http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued>

B2 Concentration Monitoring Summary

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	0	-	-	-	-	20
Total suspended solids	milligrams per litre	Special Frequency 1	0	-	-	-	-	30

Comments:

Monitoring Point 4: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	16.9	18.3	19.4	NA*



Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

13 November 2024

Discharge and Monitoring Point 5: Discharge water quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	14.5	16.5	20.7	35

Comments: Periods where the plant is offline have been removed from this data set.

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	16.0	19.5	23.5	NA*

Comments: n/a



13 November 2024

Monitoring Point 7: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	17.1	19.6	23.2	NA*

Comments: n/a

Monitoring Point 8: Discharge water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Copper	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*
Nitrogen (total)	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
pH	pH	Monthly during discharge	0	-	-	-	-	NA*
Total Phosphorous - filtered sample	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Total suspended solids	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Zinc	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply to receiving waters

Comments: No discharge



EnergyAustralia

LIGHT THE WAY

13 November 2024

Discharge and Monitoring Point 9: Air emissions monitoring

Pollutant	Unit of Measure	No. of Samples required	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Moisture content	Percent	Continuous	8.0	8.5	8.6	NA
Nitrogen oxides	parts per million	Continuous	9.9	13.2	16.3	25
Oxygen (O2)	Percent	Continuous	13.1	13.3	13.7	NA
Temperature	Degrees Celsius	Continuous	89.6	91.6	93.4	NA
Volumetric flow rate	cubic metres per second	Continuous	291.8	372.3	412.2	NA



EnergyAustralia

LIGHT THE WAY

13 November 2024

Discharge and Monitoring Point 13: Air emissions monitoring

Pollutant	Unit of Measure	No. of Samples required	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Moisture content	Percent	Continuous	10.0	10.0	10.0	NA
Nitrogen oxides	parts per million	Continuous	10.3	13.7	17.5	25
Oxygen (O2)	Percent	Continuous	13.1	13.3	13.7	NA
Temperature	Degrees Celsius	Continuous	632.3	638.3	650.7	NA
Velocity	Meters per second	Continuous	36.9	52.3	59.4	NA
Volumetric flow rate	cubic metres per second	Continuous	327.9	470.6	534.9	NA

Notes: Moisture content substituted for conservative value of 10%
 Temperature data substituted with alternative temperature probe data due to probe failure.



EnergyAustralia
LIGHT THE WAY

13 November 2024

B3 Volume or Mass Monitoring Summary

Monitoring Point 3: Sewage volume monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date Samples collected	Lowest result	Mean result	Highest result	Licence Limit
Sewage	Kilolitres per day	Continuous	**	NA	0	0	0	100

Notes: ** Continuous data recorded via inline flow meter

Comments: